Certificate of constancy of performance

0761-CPR-1427-17-2.2

Z-3/1427/17 (no. of agreement)

iBMB MPA TU BRAUNSCHWEIG
Institut für Baustoffe, Massivbau und Brandschutz | Materialprüfanstalt für das Bauwesen

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the

construction product

Aluminium roller door with fire protection properties with the trade name 'AQUISO-II'

produced by or for

Jansen Tore GmbH & Co. KG
Am Wattberg 51
26903 Surwold
Germany

in the manufacturing plant

Surwold (Germany).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 16034 / EN 13241-1

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate has an annex with one page. This certificate was issued 2025-02-21 and will remain valid until 2030-02-20, as neither the harmonised standard, the construction product, the AVCP method nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.
The certificate was first issued on 2020-01-15.

Braunschweig

Materialprüfanstalt f. d. Bauwesen MPA BS Braunschweig

signiert/signed
Aeissen, Petra
21.02.2025
18:25:44 +01
Materialprüfanstalt für das Bauwesen (MPA BS)

Dipl.-Ing. Petra Aeissen
(Deputy Head of certification body)

DAkkS Deutsche Akkreditierungsstelle D-ZE-11267-01-00

KAT · CERTIFICATE · ZERTIFIKAT · CERTIFICATE · ZERTIFIKAT · CERTIFICATE · ZERTIFIKAT · CERTIFICATE · ZERT

ZERTIFIKAT · CERTIFICATE · ZERTIFIKAT · CERTIFICATE · ZERTIFIKAT · CERTIFICATE · ZERTIFIKAT · CERTIFICATE · ZERT

iBMB MPA TU BRAUNSCHWEIG
Institut für Baustoffe, Massivbau und Brandschutz | Materialprüfanstalt für das Bauwesen

Intended use and essential characteristics according to EN 13501-2:2016
of the aluminium roller door design 'AQUISO-II'

If the room is divided into fire and/or smoke sections
and/or in escape routes

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	x	x	x			-		x	x				

E 15 / E 20 / E 30

EI_1 15 / EI_1 20 / EI_1 30

EI_2 15 / EI_2 20 / EI_2 30

EW 20 / EW 30

C / C0 / C1 / C2

S_a / S_{200}

Basis:
Report no. K-5033-DMT-DO-VO3 dated 06.07.2021

---------- End of the certificate of constancy of performance ---------